

**Office Of The Junior Chemist, P.H.E.D.  
District Laboratory Sriganganagar (Raj)  
Bacteriological Examination Report Of Water Samples**

No:- JC/SGNR/BR/22-23/ 940

Date:- 14/09/2022

To,  
Principal  
Guru Harikrishan Public School  
Sri Ganganagar

Tehsil:-Ganganagar  
district:- Sriganganagar


Ref:- Your letter no-00 Dated- 12.09.2022 Sample taker:- Your Self

The Bacteriological examination report of the sample collected by yourself is as under

Lab Sample No.	Date & Time of Collection	Date of Examination	Source	Particulars of Sample	Coliform Organism MPN per 100ml.
1747	12.09.2022	12.09.2022	TAP	Guru Harikrishan Public School Sri Ganganagar	NIL

Remarks:- 1- Samples is not collected by laboratory.  
2- Report is not valid for water quality legal cases.

**Note: (1) Samples are not collected by laboratory.  
(2) Report is not valid for water quality legal purposes.**

  
JUNIOR CHEMIST  
(P.H.E.D. LAB.)  
SRIGANGANAGAR  
जन स्वा. अभि. विभाग  
जिला-प्रयोगशाला, श्रीगंगानगर  
डी.डी.ओ.कोड नं. : 10454



Office of the Junior Chemist  
Public Health Engineering Department, Rajasthan  
District Laboratory, Ganganagar

Report of the Chemical Examination of Water

ETNO/936  
13/9/2022

To  
Principal,  
Guru Harkishan Public School,  
Sriganganagar.

Reference No : 00, Dated : 12/09/2022

Date of Receipt : 12/09/2022

District : GANGANAGAR

Sample Taker : Sh Raman Deep

Source	Permissible Value as per B.I.S : 10500/2012		Tap
Location			Guru Harkishan Public school SGNR
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source	
Village/Town			Ganganagar (M CI)
Gram Panchayat			
Date of Collection			12/09/2022
Date of Examination			12/09/2022
Sample No.			584

Note:- All results except pH are in mg/L

	6.5 to 8.5	No relaxation	7.6
pH	6.5 to 8.5	No relaxation	7.6
Turbidity(NTU)	1	5	0
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell less
Temperature	----	----	---
Total Alkalinity	200	600	150
Total Hardness (as CaCO <sub>3</sub> )	200	600	310
Calcium (as Ca)	75	200	52
Magnesium (as Mg)	30	100	43.92
Chloride(as Cl)	250	1000	50
Sulphate(as SO <sub>4</sub> )	200	400	---
Nitrate as(NO <sub>3</sub> )	45	45	16
Fluoride	1.0	1.5	0.50
Total Dissolved Solids	500	2000	720
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	0

Note : (1) Samples are not  
collected by laboratory.  
(2) Report is not valid for  
water quality legal purposes.

Remarks : Water is Potable (P)/Unpotable (U)  
No.Lab./Tech.(chem)/2022-23/584

4021  
Junior Chemist  
PHED Laboratory, Ganganagar  
(सुधा बसल)  
कनिष्ठ रसायनज्ञ  
जन स्वा.अधि.विभाग  
जिला-प्रयोगशाला, श्रीगंगानगर  
डी.डी.ओ.कोड नं. : 10484

## PROFORAMA REGARDING HEALTH CERTIFICATE

NO. 20644

DATE. 14/09/2022

It is certified that an inspection team headed by.. HARI RAM SINGHMAAR .....with  
 designation) from.... CMHO SRI GANGA NAGAR .....(Name of Officers Department/Office)  
 inspected the... GURU HARKRISHAN PUBLIC SCHOOL, TEEN PULI ..... sri ganga nagar  
 .....(Name & Address of the  
 school) on.... 13/09/2022 .....and found that the... GURU HARKRISHAN PUBLIC SCHOOL  
 (Name of school) has safe health facilities for the students and members of staff of the institution and is  
 maintaining the hygienic sanitation condition in the school building & the campus as per the norms  
 prescribed by the Central/State/U.T. Govt.

The above valid for a period of... Two year

Signatuer with seal: YR  
 मुख्य चिकित्सा एवं स्वास्थ्य अधिकारी

Name : श्रीगंगानगर (राज.)

Designation : ड. मनमोहन गुप्ता

To,

GURU HARKRISHAN PUBLIC SCHOOL,  
 TEEN PULI, SRI GANGA NAGAR  
 RAJASTHAN

(Name &amp; Address of the Institution)